

CERTIFICATE OF CONFORMITY



Issued to: GoodWe Technologies., Ltd.
No.90 Zijin Rd., New District, Suzhou, 215011, China

For the product: Hybrid & AC-Coupled Inverter

Trade name: **GOODWE**

Type/Model: GW3K-EHA-G20, GW3.6K-EHA-G20, GW5K-EHA-G20, GW6K-EHA-G20, GW8K-EHA-G20, GW9.999K-EHA-G20, GW10K-EHA-G20, GW3K-BHA-G20, GW3.6K-BHA-G20, GW5K-BHA-G20, GW6K-BHA-G20, GW8K-BHA-G20, GW9.999K-BHA-G20, GW10K-BHA-G20

Ratings: See Annex

Manufactured by: GoodWe Technologies., Ltd.
No.90 Zijin Rd., New District, Suzhou, 215011, China

Requirements: IEC 62116:2014

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6257038.50.

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 2031-01-27 or expires upon withdrawal of one of the above mentioned standards.


Shanghai, 2026-01-27

Certificate Number: 6257038.01COC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



DEKRA Testing and Certification (Shanghai) Ltd.
No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-product-safety.com
ESA-CER-F021 v4.1

PCA-141

MODELS LIST		GW3K-EHA-G20	GW3.6K-EHA-G20	GW5K-EHA-G20	GW6K-EHA-G20	GW8K-EHA-G20	GW9.999K-EHA-G20	GW10K-EHA-G20
PV INPUT	V _{MAX} PV [Vdc]	600						
	MPP Voltage Range V _{MPP} [Vdc]	40-560						
	MPP Voltage Range for Full power [Vdc]	150-500	150-500	170-500	210-500	170-500	190-500	190-500
	Nominal PV Voltage V _{nom} [Vdc]	400						
	Start PV Voltage [Vdc]	50						
	I _{sc} PV [A]	26*2	26*2	26*2	26*2	26*4	26*4	26*4
	Max. Input Current I _{max} [A]	20*2	20*2	20*2	20*2	20*4	20*4	20*4
	Backfeed Current [A]	0						
	Overvoltage Category (OVC)	OVC II						
Battery INPUT	V _{MAX} BAT [Vdc]	550						
	Voltage Range [Vdc]	350-550						
	Start Voltage [Vdc]	380						
	Max. Charge Current [A]	11.9	14.3	19.8	23.7	31.6	35.6	35.6
	Max. Discharge Current [A]	8.7	10.5	14.5	17.4	23.2	29.0	29.0
	Overvoltage Category (OVC)	OVC II						
AC OUTPUT	Rated Output Voltage U _r [Vac]	220/230/240, L/N/PE						
	Rated Output Frequency F _{NETZ} [Hz]	50/60						
	Normal Operating Frequency Range F _n [Hz]	45-55 / 55-65						
	Rated Output Power P _E [kW]	3.0	3.6	5.0	6.0	8.0	9.999	10.0
	Max. Output Power P _{Emax} [kVA]	3.0	3.6	5.0	6.0	8.0	9.999	10.0
	Rated Output Current/ Max. Output Current [A]	13.7 @220V 13.1 @230V 12.5 @240V	16.4 @220V 15.7 @230V 15 @240V	22.8 @220V 21.8 @230V 20.9 @240V	27.3 @220V 26.1 @230V 25 @240V	36.4 @220V 34.8 @230V 33.4 @240V	43.5 @220V 43.5 @230V 41.7 @240V	43.5 @220V 43.5 @230V 41.7 @240V
	Power Factor cosφ [λ]	[-0.80. 0.80]						
	Overvoltage Category (OVC)	OVC III						

Annex to 6257038.01COC

Back up	Max. Apparent power S_{Emax} [KVA]	3.0	3.6	5.0	6.0	8.0	10.0	10.0	
	Nominal Output Apparent Power [KVA]	3.0	3.6	5.0	6.0	8.0	10.0	10.0	
	Max. Apparent power S_{Emax} (Bypass) [KVA]	6	7.2	10	12	14.5	14.5	14.5	
	Nominal Output Current / Max. Output Current [A]	@220V	13.7	16.4	22.8	27.3	36.4	43.5	43.5
		@230V	13.1	15.7	21.8	26.1	34.8	43.5	43.5
		@240V	12.5	15	20.9	25	33.4	41.7	41.7
	Max. Output Current (Bypass) [A]	27.3	32.8	45.5	50	63	63	63	
	Rated Output Voltage U_r [Vac]	220/230/240, L/N/PE							
Rated Output Frequency F_{NETZ} [Hz]	50/60								
SYSTEM	Protective Class	I							
	Enclosure Protection (IP)	IP66							
	Operating Temperature Range [°C]	-35 to +60 (>40 derating)							
	Pollution degree (PD)	External PD3/Internal PD 2							
	Altitude [m]	Max. 4000							
	Weight [kg]	24	24	24	24	26	26	26	
	Size [mm] (W*H*D mm)	800*300*270							
	Type of inverter	Transformerless							
	Firmware version	010101							
Note: N/A									

MODELS LIST		GW3K-BHA-G20	GW3.6K-BHA-G20	GW5K-BHA-G20	GW6K-BHA-G20	GW8K-BHA-G20	GW9.999K-BHA-G20	GW10K-BHA-G20
Battery INPUT	V _{MAX} BAT [Vdc]	550						
	Voltage Range [Vdc]	350-550						
	Start Voltage [Vdc]	380						
	Max. Charge Current [A]	7.9	9.6	13.2	15.8	21.1	26.4	26.4
	Max. Discharge Current [A]	8.7	10.5	14.5	17.4	23.2	29.0	29.0
	Overvoltage Category (OVC)	OVC II						
AC OUTPUT	Rated Output Voltage Ur [Vac]	220/230/240, L/N/PE						
	Rated Output Frequency F _{NETZ} [Hz]	50/60						
	Normal Operating Frequency Range F _n [Hz]	45-55 / 55-65						
	Rated Output Power P _E [kW]	3.0	3.6	5.0	6.0	8.0	9.999	10.0
	Max. Output Power P _{Emax} [kVA]	3.0	3.6	5.0	6.0	8.0	9.999	10.0
	Rated Output Current / Max. Output Current [A]	13.7 @220V 13.1 @230V 12.5 @240V	16.4 @220V 15.7 @230V 15 @240V	22.8 @220V 21.8 @230V 20.9 @240V	27.3 @220V 26.1 @230V 25 @240V	36.4 @220V 34.8 @230V 33.4 @240V	43.5 @220V 43.5 @230V 41.7 @240V	43.5 @220V 43.5 @230V 41.7 @240V
	Power Factor cosφ [λ]	[-0.80. 0.80]						
Overvoltage Category (OVC)	OVC III							
Back up	Max. Apparent power S _{Emax} [KVA]	3.0	3.6	5.0	6.0	8.0	10.0	10.0
	Nominal Output Apparent Power [KVA]	3.0	3.6	5.0	6.0	8.0	10.0	10.0
	Max. Apparent power S _{Emax} (Bypass) [KVA]	6	7.2	10	12	14.5	14.5	14.5
	Nominal Output Current / Max. Output Current [A]	13.7 @220V 13.1 @230V 12.5 @240V	16.4 @220V 15.7 @230V 15 @240V	22.8 @220V 21.8 @230V 20.9 @240V	27.3 @220V 26.1 @230V 25 @240V	36.4 @220V 34.8 @230V 33.4 @240V	43.5 @220V 43.5 @230V 41.7 @240V	43.5 @220V 43.5 @230V 41.7 @240V
	Max. Output Current (Bypass) [A]	27.3	32.8	45.5	50	63	63	63

Annex to 6257038.01COC

	Rated Output Voltage Ur [Vac]	220/230/240, L/N/PE						
	Rated Output Frequency F _{NETZ} [Hz]	50/60						
SYSTEM	Protective Class	I						
	Enclosure Protection (IP)	IP66						
	Operating Temperature Range [°C]	-35 to +60 (>40 derating)						
	Pollution degree (PD)	External PD3/Internal PD 2						
	Altitude [m]	Max. 4000						
	Weight [kg]	16.9	16.9	16.9	16.9	17.7	17.7	17.7
	Size [mm] (W*H*D mm)	800*300*270						
	Type of inverter	Transformerless						
	Firmware version	010101						
	Note: N/A							