ATTESTATION OF CONFORMITY

Issued to: Goodwe Technologies Co., Ltd

No.90 ZiJin Rd., New District, Suzhou, 215011, China

For the product: Hybrid Inverter

Trade name: GOODWE

Type/Model: GW5K-ET-L-G10, GW6K-ET-L-G10, GW10K-ET-L-G10, GW12K-

ET-L-G10, GW15K-ET-L-G10, GW20K-ET-L-G10, GW12K-ET-LL-G10

Ratings: See annex

Manufactured by: Goodwe Technologies Co., Ltd

No.90 ZiJin Rd., New District, Suzhou, 215011, China

Subject: Complete evaluation of electrical system of the appliances

Requirements: IEC 62109-1:2010, EN 62109-1:2010

IEC 62109-2:2011, EN 62109-2;2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 6210814.50(A-B)

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen of several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA/is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

The CE marking may be affixed on the product if all relevant and effective EU regulations are complied with.

Arnhem, 1 July 2025 Number: 6210814.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin

Certification Manager

Page 1 of 3

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd. 5F #250 Jiangchangsan Road Shibei Hi-Tech Park, 200436 Jing'an District, Shanghai, China

T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com

Annex: 6210814.01AOC



_	ı		T	T	T	T	T	T		
GoodWe	GW5K-	GW6K-	GW8K-	GW10K	GW12K	GW15K	GW20K	GW12K-		
	ET-L- G10	ET-L-	ET-L-	-ET-L-	-ET-L-	-ET-L-	-ET-L-	ET-LL- G10		
Battery Side	GIU	G10	G10	G10	G10	G10	G10	GIU		
_					40					
Nominal BAT Voltage (V)	48									
Battery voltage range (V)	40~60									
Start-up Voltage(V)	30									
Max, Continuous Charging Current (A)	125	135	175	220	250	165/ 165	208/ 208	250		
Max, Continuous Discharging Current (A)	125	135	175	220	250	165/ 165	208/ 208	250		
Max Charge Power (kW)	5,0	6,0	8,0	10,0	12,0	15,0	20,0	12,0		
Max Discharge Power (kW)	5,5	6,6	8,8	11,0	13,2	16,5	22,0	13,2		
PV Side	l .		l .	I.	l .	l	l .			
Max, Input Power (kW)	10	12	16	20	24	30	40	24		
Max, Input Voltage (V)	1000									
MPPT Operating Voltage Range (V)	150-850									
MPPT Operating Voltage										
Range at Nominal Power (V)	300~850 350~850						~850	300~ 850		
Start-up Voltage (V)	180									
Nominal Input Voltage (V)	620									
Max, MPPT Current (A)	20/20			20/20/20		20/20/20/20		20/20/20		
Max, MPPT Short Circuit Current(A)	26/26			26/26/26		26/26/26/26		26/26/26		
Number of Strings per MPPT	2/1+1			3/1+1+1		4/1+1+1+1		3/1+1+1		
AC Side (On-grid)										
Nominal Power (kW)	5,0	6,0	8,0	10,0	12,0	15,0	20,0	12,0		
Max, Power (kW)	5,5	6,6	8,8	11,0	13,2	16,5	22,0	12,0		
Nominal Apparent Power Output to Grid (kVA)	5,0	6,0	8,0	10,0	12,0	15,0	20,0	12,0		
Max, Apparent Power to Utility Grid (kVA)	5,5	6,6	8,8	11,0	13,2	16,5	22,0	13,2		
Nominal Apparent Power from Grid(kVA)	5,0	6,0	8,0	10,0	12,0	15,0	20,0	12,0		
Nominal Voltage (V)	400/380, 3L/N/PE									
Voltage Range (V)	170~290									

Annex: 6210814.01AOC



Nominal Frequency (Hz)	50/60 60										
Max, Current from Grid											
(A)	70										
Max, Output Fault											
Current (Peak and	99										
Duration) (A)											
Power Factor	~1 (Adjustable from 0,8 leading~ 0,8 lagging)										
Max Output Overcurrent	70										
Protection (A)											
Backup Side		I	1	I	I	1	I				
Nominal Output Apparent Power (kVA)	5,0	6,0	8,0	10,0	12,0	15,0	20,0	12,0			
Max, Output Apparent Power (kVA)	5,5	6,6	8,8	11,0	13,2	16,5	22,0	13,2			
Max, Output Apparent Power with Grid (kVA)	48,3										
Max Output Current (Byapss)	70										
Maximum Overcurrent Protection (A)	70										
Nominal Output Voltage (V)	400/380, 3L/N/PE										
Nominal Output Frequency (Hz)	50/60										
Generator Side											
Nominal Apparent Power(kVA)	20,0										
Max, Apparent Power (kVA)	20,0										
Nominal Voltage (V)	400/380							220			
Input Voltage Range (V)	170~290										
Nominal Frequency (Hz)	50/60										
Max, Current (A)	30,3										
General Data	Over voltage category: III(Mains), II(PV), Operating temperature range: - 35 °C to + 60 °C, Relative Humidity (%): 0-95, Protective class: I, Ingress protection rating: IP66, Operating Altitude (m): 4000, Mounting Method: Wall Mounted, Cooling Method: Smart Fan Cooling										

END