

Certificate Number: AZ 69027417

Page: 0005



CERTIFICATE OF APPROVAL

Authorised marking: TUV-027417-EA

CONTINUATION SHEET 4

(Modification 3)

Classified as:

Installed within power conditioning equipment (PCE),
enclosed outdoor, suitable for installation exposed to
sunlight as per AS/NZS 5033.

Switch arrangement: GHX6-55P, 8 layers

Installed within Hybrid Inverter

Ithe Solar at 40°C: MPP1&3: 42A, MPP2&4: 32A

Ithe Solar at 60°C: MPP1&3: 42A, MPP2&4: 32A

Brand: GOODWE

Models: GW40K-ET-10, GW50K-ET-10

Size: 520mm×660mm×260mm (W x H x D)

Enclosure material: Aluminum

Issue Date: 14/08/2024

Expiry Date: 25/05/2027

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read "John Wang".

John Wang



www.jas-anz.org/register