

To / 致:

Company / 公司: GoodWe (GuangDe) Power Supply Technology Co., Ltd.

Contact / 联系人: Ms. Zhai Yingqian
Email / 邮箱: Yingqian.zhai@goodwe.com

From / 自:

Company / 公司: TÜV NORD (HANGZHOU) CO., LTD. / 杭州汉德质量认证服务有限公司

Contact / 联系人: Mrs. Serena.Wu / 郭玉婷 女士
Email / 邮箱: sewu@tuv-nord.com

Subject: Announcement of cancellation

主题: 证书取消通知

File No.: PVP07058/23P-03

项目号:

License holder: GoodWe (GuangDe) Power Supply Technology Co., Ltd.

持证人:

Certificate No.: 44 780 24 406749 - 071

证书号:

Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

产品: 地面用晶体硅光伏组件

Herewith it is declared, that the above noted certificate(s) has (have) been invalidated since 2024-03-27.
特此声明, 上述证书自 2024 年 3 月 27 日起失效。

The cancellation is due to:

取消原因:

License holder applied for cancellation.

持证人申请取消。

New certificate(s) (no: 44 780 24 406749 - 071R1M1__) has (have) been issued to replace the cancelled one(s).

新证书 (证书号: __44 780 24 406749 - 071R1M1__) 签发, 取代旧证书。

Certificate(s) is (are) expired.

证书有效期至。

Certificate(s) has (have) been suspended for one year, and the factory inspection, verification, and rectification required to restore the certificate(s) has (have) not been completed.

证书暂停满一年, 未完成恢复证书所需厂检、核查、整改等。

Certificate(s) has (have) been suspended for one year, and the annual certificate fee has (have) not been paid.

证书暂停满一年, 未支付证书年费。

Others: _____

其他情况: _____

Please pay attention to stop using the invalid certificate(s) from 2024-03-27. Meanwhile, please send back the original copies of above mentioned certificate(s) to us.

请注意从 2024 年 3 月 27 日开始停止使用无效证书。同时，请将上述证书原件寄回给我们。

TÜV NORD reserved the right of final explanation about the cancellation of certificate(s). TÜV NORD will not take any responsibility for the circumstance of misusing the invalid certificate(s) by the license holder or the manufacturer.

TÜV NORD 保留对证书取消的最终解释权。TÜV NORD 对证书持有者或制造商滥用无效证书的情况不承担任何责任。

Renewable Energy / 可再生能源

TÜV NORD (Hangzhou) Co., Ltd. / 杭州汉德质量认证服务有限公司



Serena.Wu / 郭玉婷

Technical Support / 技术支持

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

GoodWe (GuangDe) Power Supply Technology Co., Ltd.
No.208, Tong Rui East Road, Guangde,
Anhui
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2024-03-27

Valid until: 2029-02-27

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC 61215-1:2021 / EN IEC 61215-1:2021; IEC 61215-1-1:2021 / EN IEC 61215-1-1:2021; IEC 61215-2:2021 / EN IEC 61215-2:2021; IEC 61730-1:2016 / EN IEC 61730-1:2018; IEC 61730-2:2016 / EN IEC 61730-2:2018.
Registered No.:	44 780 24 406749 - 071R1M1
Manufacturer and factory(-ies):	See Annex 1
Test Report No.:	492013002.002
File No.:	PVP07058/23P-04



TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2024-03-27

Please also pay attention to the information stated overleaf.

Manufacturer and factory(-ies):

Manufacturer: **GoodWe (GuangDe) Power Supply Technology Co., Ltd.**
No.208, Tong Rui East Road, Guangde, Anhui, P.R. China

Factory: **GoodWe (GuangDe) Power Supply Technology Co., Ltd.**
No.208, Tong Rui East Road, Guangde, Anhui, P.R. China

Factory inspection report no.: 862010575.003

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:

PV Modules with 182mm Mono-crystalline Silicon Half-cut Solar Cells:

- 156 cells: BMT-P2/156A (xxxW) (xxx=615-635, in steps of 5)
- 144 cells: BMT-P2/144A (xxxW) (xxx=540-560, 570-585, 595-635, in steps of 5)
- 132 cells: BMT-P2/132A (xxxW) (xxx=495-510, 525-540, 550-615, in steps of 5)
- 120 cells: BMT-P2/120A (xxxW) (xxx=450-465, 475-490, 500-525, in steps of 5)
- 108 cells: BMT-P2/108A (xxxW) (xxx=405-420, 430-440, 450-475, in steps of 5)
- 96 cells: BMT-P2/096A (xxxW) (xxx=360-370, 380-390, 400-420, 430-445, in steps of 5)
- 80 cells: BMT-P2/080A (xxxW) (xxx=300-310, 320-325, 335-350, in steps of 5)
- 32 cells: BMT-S2/032A (xxxW) (xxx=80-120, 130-140, in steps of 5)
- 32 cells: BMT-S2/032B (xxxW) (xxx=80-120, 130-140, in steps of 5)
- 24 cells: BMT-S2/024A (xxxW) (xxx=82, 84, 87, 89, 91, 93, 95, 97, 99, 101, 103, 105)
- 24 cells: BMT-S2/024B (xxxW) (xxx=82, 84, 87, 89, 91, 93, 95, 97, 99, 101, 103, 105)
- 12 cells: BMT-S2/012A (xxxW) (xxx= 41, 43, 45, 49, 51, 53)
- 12 cells: BMT-S2/012B (xxxW) (xxx= 41, 43, 45, 49, 51, 53)
- 6 cells: BMT-S2/006A (xxxW) (xxx= 21, 23, 25)
- 6 cells: BMT-S2/006B (xxxW) (xxx= 21, 23, 25)
- 208 cells: BMT-L2/208A (xxxW) (xxx=520-730, in steps of 5)
- 144 cells: BMT-L2/144A (xxxW) (xxx=360-550, 570-585, 595-635, in steps of 5)
- 112 cells: BMT-L2/112A (xxxW) (xxx=280-425, 445-455, 465-490, in steps of 5)
- 96 cells: BMT-L2/096A (xxxW) (xxx=240-365, 380-390, 400-420, in steps of 5)
- 80 cells: BMT-L2/080A (xxxW) (xxx=200-305, 320-325, 335-350, in steps of 5)
- 72 cells: BMT-L2/072A (xxxW) (xxx=180-275, 285-290, 300-315, in steps of 5)
- 39 cells: BMT-L2/039A (xxxW) (xxx=100-145, 155, 165-170, in steps of 5)
- 36 cells: BMT-L2/036A (xxxW) (xxx=90-135, 145-155, in steps of 5)
- 30 cells: BMT-L2/030A (xxxW) (xxx=75-110, 120-130, in steps of 5)
- 27 cells: BMT-L2/027A (xxxW) (68W, 72W, 76W, 80W, 84W, 88W, 92W, 96W, 100W, 103W, 107W, 109W, 112W, 115W, 119W)



TÜV NORD CERT GmbH
Certification Body
Consumer Products

24 cells: BMT-L2/024A(xxxW) (60W, 64W, 68W, 72W, 76W, 80W, 84W, 88W, 91W, 95W, 97W, 100W, 103W)

20 cells: BMT-L2/020A (xxxW) (50W, 53W, 56W, 59W, 62W, 65W, 68W, 70W, 73W, 76W, 85W, 88W)

15 cells: BMT-L2/015A (xxxW) (38W, 41W, 44W, 47W, 50W, 53W, 57W, 60W, 63W, 66W)

10 cells: BMT-L2/010A (xxxW) (25W, 28W, 31W, 34W, 38W, 44W)

60 cells: BMW-D2/060A (xxxW) (xxx=150-225, 240, 250-260, in steps of 5)

48 cells: BMW-D2/048A (xxxW) (xxx= 120-180, 190-210, in steps of 5)

42 cells: BMW-D2/042A (xxxW) (xxx=105-160, 170-185, in steps of 5)

28 cells: BMW-D2/028A (xxxW) (xxx=70W, 74W, 78W, 82W, 86W, 90W, 94W, 98W, 102W, 106W, 118W, 122W)

14 cells: BMW-D2/014A (xxxW) (xxx=35W, 38W, 41W, 44W, 47W, 50W, 53W, 56W, 59W)

78 cells: BMW-K2/078A (xxxW) (xxx=195-295, 310-315, 325-340, in steps of 5)

72 cells: BMW-K2/072A (xxxW) (xxx=180-275, 285-290, 300-315, in steps of 5)

40 cells: BMW-K2/040A (xxxW) (xxx=130-150, 160, 170-175, in steps of 5)

72 cells: BMW-B2/072A (xxxW) (xxx=180-275, 285-290, 300-315 in steps of 5)

54 cells: BMW-B2/054A (xxxW) (xxx=135-205, 215, 225-235, in steps of 5)

Remark: The power parameter included in the module types only indicates maximum power output of front side.

Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	4800Pa/ 1600Pa or 3600Pa/ 1600Pa or 1600Pa / 1600Pa, refer CDF for details
Safety factors:	1.5
Fire safety class:	Class A according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form).



TÜV NORD CERT GmbH
Certification Body
Consumer Products